



# USER MANUAL FOR SOLI



# **USER MANUAL FOR SOLI**

1.	Foreword	3
2.	Introduction	3
3.	Warning And Definition Stickers On The Case	4
4.	Norms And Certificates	5
5.	Installation And Environmental Situations	5
6.	Care And Cleaning	6
7.	Electricity Connection	7
8.	Recycle Parts	7
9.	Loading Goods	8
10.	Technical Details	9



#### 1. Foreword

Dear Customer,

Please be sure to read this operating manual carefully before putting your new device into use. The manual contains important notes on safety and proper installation, use and maintenance of the device.

Please keep the manual ready for reference and hand it over to any future new owner of the device. Make sure the manual is read by all staff who may use or work with the cabinets and that they understand and observe the contents.

To ensure safe operation in all service conditions, the following safety precautions must be observed:

- Contact your Service Organization if you are in any doubt about electrical connection, working or safety of your refrigerated cabinets.
- Never detach any cover except where specifically instructed in this manual. Doing so might expose live electrical parts.
- Never use a water hose or high-pressure jet to clean the device.
- All work on electrical equipment must be left to a qualified electrician.
- Please pay attention to the maximum load limits when filling the display shelves.
- Electrical elements may only be replaced by a qualified electrician or person with experience in electrical engineering!
- Wear safety gloves when cleaning and servicing the device.

Ahmet Yar cabinets does not contain PCB, PCT, asbestos, formaldehyde, cadmium or substances which interfere with moistening.

Producer company does not have any responsibilities about the situations below:

Wrong usage of the refrigerator, Wrong assembling, Electrical Effects, Not doing the periodical cares, Changes of operation, Not using the original spare parts, Ignoring the given infos.

(Some of the explanations and applications may vary depending on the device type and model.)

#### 2. Introduction

This guide is prepared for the SOLI cabinet. The details below are examined in general; How the refrigerator will be used, technical details, installation and assembling infos and suggestions for the users-care operations.


SOLI is a semi-vertical, open-front, multi-shelfed cooler refrigerator. Its condenser unit is designed as remote. With its wide display area and loading capacity, it is suitable for usage of stores and larger stores.

Cheese in the cabinet. The cabinet has a defrost-type off-cycle. Run cases modules are 1875 mm, 2500 mm and 3750 mm



#### 3. Warning and definition stickers on the case

- Product Definition Sticker (Fig.1): Product definition sticker is located inside the cabinet on the ceiling and it can includes all technical properties as below: Logo and address info of the producer company, product certificates and quality certificates of the producer, model of the product, article no, serial number of the product, production date of the product, air conditioner class of the product, temperature range of the cabinet, type of refrigerant, test pressure, working pressure, working voltage info, approved certificates of the product and the standards&directives, fans supply voltage info, power of evaporator fans, power of led lights, power of drain heaters, power of defrost heaters, power of glass heaters, load max.. etc.
- High Voltage Sticker (Fig.2): High voltage sticker is located on the electricity box.
- Loading Sticker (Fig.3): There are palettes located on the refrigerator for transportation.
   Transportations with forklifts or transpalettes are materialized by the assistance of these palettes. There is a sticker behind the refrigerator about the transportation palettes.
- Fragile Stciker (Fig.4): There ara on the risk of fracture surfaces. Carefully moving is important and do not hit to hard materials. There are fra-gile stickers on the side walls.
- Foot Print Sticker (Fig.5): This sticker located on the base trays.
- Pressure Sticker (Fig.6): Pressure sticker is located at the exit points of the copper pipes. It is used for determining the quantity of nitrogen.





#### 4. Norms and Certificates

The approved certificates of norms and refrigerators that are using as reference; EN 60204-1; EN 60439-1; EN 60439-2

**ENVIRONMENTAL CLIMATIC ATMOSPHERE (EN 441-4)** 

This refrigerator is tested as to atmosphere heat class 3.

Class	Dry Air Temparature	Relative Humidity	Dew Point
1	16°C	%80	12°C
2	22°C	%65	15°C
3	25°C	%60	17°C
4	30°C	%55	20°C
5	40°C	%40	24°C
6	27°C	%70	21°C


The directives that the refrigerator suits EEC 73/23, EEC 98/37

#### 5. Installation and Environmental Situations


Follow the instructions below for installation.

The situations that must be paid attention to placing the cabinets. Do not leave or assemble the refrigerator at the positions below;

- Do not place the cabinet under direct sunlight
- Do not place the cabinet in front of a door
- Do not place the cabinet near a heat sources
- Do not place the cabinet in front of direct air flow from an air condition or a vantilator.
- Do not place the cabinet outdoors











## 6. Care and Cleaning

Long life and satisfactory performance of any equipment is dependent upon the care it receives. To ensure long life, proper sanitation and minimum maintenance costs, these display Cases should thoroughly cleaned, all debris removed and the interiors washed down, weekly.



#### **Fan Plenum**

To facilitate cleaning, the fan plenum is hinged and also fastened with screws at each end. After cleaning be sure the plenum is properly lowered into position and that screws are reinstalled or product loss will result due to improper refrigeration.

#### **Exterior Surfaces**

The exterior surfaces should clean with a mild detergent and warm water to protect and maintain their attractive finish. Never use abrasive cleaners or scouring pads.

#### **Interior Surfaces**

The interior surfaces may cleaned with most domestic detergents, ammonia based cleaners and sanitizing solutions with no harm to the surface.

#### DO NOT USE:

Abrasive cleansers and scouring pads, as these will mar the finish. Solvent, oil or acidic based cleaners on any interior surfaces.



#### DO:

Remove the product and all loose debris to avoid clogging the waste outlet. Store product is in a refrigerated area such as a freezer. Remove only as much product as can be taken to the freezer in a timely manner.

First turn off refrigeration, and then disconnect electrical power.

Thoroughly clean all surfaces with soap and hot water. Do not use steam or high water pressure hoses to wash the interior. This will destroy the display cases sealing causing leaks and poor performance.



Remove screws and lift fan plenum for cleaning. Be sure to reposition the fan plenum after cleaning display cases.

Take care to minimize direct contact between fan motors and cleaning or rinse water. Rinse with hot water, but do not flood. Never introduce water faster than the waste outlet can remove it.

Allow display cases to dry before resuming operation.

After cleaning completed, turn on power and refrigerant to the Display Case. Verify that display case is working properly.

## 7. Electricity Connection

Details below must be examined while making the electrical connections.



- Protective automatic key and main power switch must be used against electric current on the device. Users must know where the key is kept in case of an emergency.
- Electric systems must be grounded.
- Maximum voltage difference must be guarantied at %+-6.
- The thickness of the cable on the energy line must be at least 2,5 mm2 and must put up with high current.
- The cable of energy line must not be longer than 4-5m, depends on the conditions if cable length increases the cable cross-section must be increased too.
- For making the device works regularly, be sure you obtained the heat and the damp values which are regarded at EN441 and be sure the climate class is 3. (+25°C;R.H. 60%)
- The personnel who will interfere to the device must have electricity certificate.

#### 8. Recycle Parts

All countries are disposing of waste according to EU laws and norms. Current Recycle Parts on the case;

Painted Metals: Pillars, shelves, legs, back panel, base tray, ceiling. Cupper-Aluminium: Condanser, evaporator and electrical parts.

Galvanised Steels: Bottom panels, painted panels, basic parts, base tray.

Polyurethane: Thermal injection.

Thermopane: Glass parts.

PVC: Handrails.

Polystyrene: Thermoform side endwalls.


Polycarbon: Lighting cover.



# 9. Loading Goods

Cabinet loading important rules that should be followed.

- Locate the goods to the shelves tidy.
- The overall load does not exceed the capacity of the shelves (160 kg/ m²).
- Shelves can be adjusted at different angles according to the device type (0°, 10°, 20°).
- To install packages in the closet, set max and do not leave blank space.
- Between the top shelf loaded with goods leave the 30mm gap.
- Ensure consumption of the substance and accordingly load.
- Except for the closet shelf and the base tray, do not install any goods.
- Do not obstruct the flow of refrigerated air.



9



# 10. Technical Details



# TECHNICAL DATA SHEET - SOLI 1100 Sushi Cabinet

TECHNICAL DETAILS	1875 mm	2500 mm
-------------------	---------	---------

Re	Refrigeration Load							
Temp Class (prEN ISO 23953-2)	3M(	)						
Case Temp (°C)	-1/-	+4						
Evap Temp (°C)	-10	)						
Duty (kW)	2,04	2,66						
Expansion Valve (R744 - 65 bar)	AKVH 10-2	AKVH 10-3						
Pipe Size - Suction	3/8"	3/8"						
Pipe Size - Liquid	3/8"	3/8"						
Expansion Valve (R404)	AKV 10-3	AKV 10-4						
Pipe Size - Suction	5/8"	5/8"						
Pipe Size - Liquid	3/8"	3/8"						
Pipe Size - Drain	28 mm							
Cubic Capacity (dm³)								
Display Area (m²)								

Defrost Details							
Defrost Type Air Air							
Duration (minutes)	45 min x 6	45 min x 6					
Termination	Temp	Temp					

	Heaters			
Evaporator (Coil)	-	_	_	_
(11)	_	_	_	_
Frame (Schott Termofrost)	_	_	_	_
Doors (Schott Termofrost)	-	_	_	_
Front Glass	-	_	_	_
Side Glass	_	_	_	_
End Walls	_	_	_	_
Body	_	_	_	_
Water Drain	_	_	_	_
Air Return	_	_	_	_




			1	ı
Air Intake	_	_	_	_

Electrical / Fans							
Supply		230 V / 50 Hz					
Exp. Valve Coil ( Da	nfoss 018F6802)	12 W					
Lighting LED Nualight	t Alto 520 4000K	56 W 84 W					
Evaporator Fans	ELCO ECM HC 12-10-2	800 rpm - 200 mm /A 22°					
		4,5 W x 3	4,5 W x 4				

Air Flow Info						
Air Speed on honeycomb	0.9 m/s at ambient conditions					


	TECHNICAL	CHAPTER REVISION STATUS							
filmet yar	DOCUMENTATION	ORD.	DATE	CHANGE ORDER	ORD.	DATE	CHANGE ORDER		
PRODUCT	Soli 1100	А			D				
DATE of 1st ISSUE	22.12.2014	В			E				
ORDER	ULAS GÜDÜCÜ	С			F				






SDLI 1100





SOLI 1200





SOLI 1500



		SOLI SPARE PARTS LIST										
NO	CODE	NARAE	SOLI 1100		00	SOLI 1200			SOLI 1500			UNIT
NO CODE		NAME	1875	2500	3750	1875	2500	3750	1875	2500	3750	UNII
	49402081	SOLI ON EMIS SACI 1250 MM SAG BOYALI		1	1		1	1		1	1	PCS
1	49402082	SOLI ON EMIS SACI 1250 MM SOL BOYALI		1	2		1	2		1	2	PCS
1	49401081	SOLI ON EMIS SACI 937 MM SAG BOYALI	1			1			1			PCS
	49401082	SOLI ON EMIS SACI 937 MM SOL BOYALI	1			1			1			PCS
	49403050	SOLI ON DEKOR MDF'SI 1875 MM	1			1			1			PCS
2	49404050	SOLI ON DEKOR MDF'SI 2500 MM		1			1			1		PCS
	49406050	SOLI ON DEKOR MDF'SI 3750 MM			1			1			1	PCS
	49403002	SOLI ON DEKOR SACI 1875 MM BOYALI	1			1			1			PCS
3	49404002	SOLI ON DEKOR SACI 2500 MM BOYALI		1			1			1		PCS
	49406002	SOLI ON DEKOR SACI 3750 MM BOYALI			1			1			1	PCS
	48103053	MDM03 BAZA SACI 1875 MM BOYALI	1			1			1			PCS
4	48104053	MDM03 BAZA SACI 2500 MM BOYALI		1			1			1		PCS
	48106053	MDM03 BAZA SACI 3750 MM BOYALI			1			1			1	PCS
5	10410203	BAZA LASTIGI YENI TIP 2550 mm (R07 SIYAH) (60008)		1			1			1		PCS
5	10410202	BAZA LASTIGI YENI TIP 3800 mm (R07 SIYAH) (60008)	0,5		1	0,5		1	0,5		1	PCS
	38703003	FM 130 FAN SACI 1875 MM	1			1			1			PCS
6	38704003	FM 130 FAN SACI 2500 MM		1			1			1		PCS
	38706003	FM 130 FAN SACI 3750 MM			1			1			1	PCS
7	20830033	ENERGY SAVING FAN ECM HC 12-10 (EFA12100VC0421N) 2	3	4	6	3	4	6	3	4	6	PCS
7.1	20850102	FAN MONTAJ CEMBER TERMOPLASTIK 200	3	4	6	3	4	6	3	4	6	PCS
7.2	20840102	FAN KANAT EMIS 200-22	3	4	6	3	4	6	3	4	6	PCS
7.3	20860016	SPG FAN MUHAFAZA TELI Ø 200 SIYAH	3	4	6	3	4	6	3	4	6	PCS
	39403051	SOLI EVAPORATOR ORTME SACI 1875 MM	1			1			1			PCS
8	39404051	SOLI EVAPORATOR ORTME SACI 2500 MM		1			1			1		PCS
	39406051	SOLI EVAPORATOR ORTME SACI 3750 MM			1			1			1	PCS



	49401056	SOLI TAVA 755*468 MM BOYALI	4			4			4			PCS
9	49402056	SOLI TAVA 755*625 MM BOYALI		4	6		4	6		4	6	PCS
10	23700225	TAVA TAPASI - GRI	4	4	6	4	4	6	4	4	6	PCS
11	24019908	CIVATA AYAK M16*90 (LASTIKLI)	6	6	8	6	6	8	6	6	8	PCS
	49401015	SOLI 1100 ARKA TEL SAG 937 MM BOYALI	1									PCS
	49401017	SOLI 1100 ARKA TEL SOL 937 MM BOYALI	1									PCS
	49402015	SOLI 1100 ARKA TEL SAG 1250 MM BOYALI		1	1							PCS
	49402016	SOLI 1100 ARKA TEL ORTA 1250 MM BOYALI			1							PCS
	49402017	SOLI 1100 ARKA TEL SOL 1250 MM BOYALI		1	1							PCS
	49601015	SOLI 1200 ARKA TEL SAG 937 MM BOYALI				1						PCS
	49601017	SOLI 1200 ARKA TEL SOL 937 MM BOYALI				1						PCS
12	49602015	SOLI 1200 ARKA TEL SAG 1250 MM BOYALI					1	1				PCS
	49602016	SOLI 1200 ARKA TEL ORTA 1250 MM BOYALI						1				PCS
	49602017	SOLI 1200 ARKA TEL SOL 1250 MM BOYALI					1	1				PCS
	49701015	SOLI 1500 ARKA TEL SAG 937 MM BOYALI							1			PCS
	49701017	SOLI 1500 ARKA TEL SOL 937 MM BOYALI							1			PCS
	49702015	SOLI 1500 ARKA TEL SAG 1250 MM BOYALI								1	1	PCS
	49702016	SOLI 1500 ARKA TEL ORTA 1250 MM BOYALI									1	PCS
	49702017	SOLI 1500 ARKA TEL SOL 1250 MM BOYALI								1	1	PCS
	49403005	SOLI UST KAPAMA SACI 1875 MM BOYALI	1			1			1			PCS
13	49404005	SOLI UST KAPAMA SACI 2500 MM BOYALI		1			1			1		PCS
	49406005	SOLI UST KAPAMA SACI 3750 MM BOYALI			1			1			1	PCS
14	49401021	SOLI DEFLEKTOR SACI 937 MM BOYALI	2			2			2			PCS
	49402021	SOLI DEFLEKTOR SACI 1250 MM BOYALI		2	3		2	3		2	3	PCS
15	21070433	SUTLUK PERDE FRENLI - KULPLU (DELIKSIZ)	2			2			2			PCS
	21070434	SUTLUK PERDE FRENLI - KULPLU (DELIKSIZ)		2	3		2	3		2	3	PCS




		I		1	ı	1	ı	I		1	1	
	49403025	SOLI 1100 PERDE ORTME SACI 1875 MM BOYALI	1			1			1			PCS
16	49404025	SOLI 1100 PERDE ORTME SACI 2500 MM BOYALI		1			1			1		PCS
	49406025	SOLI 1100 PERDE ORTME SACI 3750 MM BOYALI			1			1			1	PCS
	48701054	FM-130 ARI PETEGI ALT SACI 937MM BOYALI	2			2			2			PCS
17	48702054	FM-130 ARI PETEGI ALT SACI 1250MM BOYALI		2	3		2	3		2	3	PCS
	21030203	ARI PETEGI 1000*95*25 mm GRI - D:3 mm	2			2			2			PCS
18	21030205	ARI PETEGI 1250*95*25 mm GRI - D:3 mm		2	3		2	3		2	3	PCS
	40003096	FM-130 RAF KOLU 300MM BOYALI										PCS
19	40003097	FM-130 RAF KOLU 400MM BOYALI										PCS
	40003098	FM-130 RAF KOLU 500MM BOYALI										PCS
	40001096	FM-130 RAF 300MM 937MM BOYALI										PCS
	40001097	FM-130 RAF 400MM 937MM BOYALI										PCS
20	40001098	FM-130 RAF 500MM 937MM BOYALI										PCS
20	40002096	FM-130 RAF 300MM 1250MM BOYALI										PCS
	40002097	FM-130 RAF 400MM 1250MM BOYALI										PCS
	40002098	FM-130 RAF 500MM 1250MM BOYALI										PCS
21	22340205	ALTO 500 SILVER 927 mm. 4000 K. (L-BRK+CABLE) 21 W	4			4			4			PCS
21	22340203	ALTO 520 SILVER 1240 mm. 4000 K. (L-BRK+CABLE) 26W		4	6		4	6		4	6	PCS
22	23640802	TD 2012 RAF SIPERLIGI 937 mm.	4			4			4			PCS
22	23640170	TD 2012 RAF SIPERLIGI 1250mm.		4	6		4	6		4	6	PCS
22	10410154	RAF ETIKETLIGI (AGEAN-WDM) 937 mm R01 BEYAZ (52045)	4			4			4			PCS
23	10410152	RAF ETIKETLIGI (WDM-AGEAN) 1250 mm R01 BEYAZ (52045)		4	6		4	6		4	6	PCS
	23620462	SOLI 1100 YAN CAM SECURIT (FOR AHOLD)	2	2	2							PCS
24	23620491	SOLI 1200 YAN CAM SECURIT (FOR AHOLD)				2	2	2				PCS
	23610497	SOLI 1500 YAN CAM SECURIT (FOR AHOLD)							2	2	2	PCS

17



	49400288	SOLI 1100 CAMLI YAN SAG POLIURETANLI	1	1	1							PCS
	49400289	SOLI 1100 CAMLI YAN SOL POLIURETANLI	1	1	1							PCS
25	49600288	SOLI 1200 CAMLI YAN SAG POLIURETANLI				1	1	1				PCS
25	49600289	SOLI 1200 CAMLI YAN SOL POLIURETANLI				1	1	1				PCS
	49700288	SOLI 1500 CAMLI YAN SAG POLIURETANLI							1	1	1	PCS
	49700289	SOLI 1500 CAMLI YAN SOL POLIURETANLI							1	1	1	PCS
	49400005	SOLI 1100 CAMLI YAN CAM KILIF SACI BOYALI	1	1	1							PCS
26	49600005	SOLI 1200 CAMLI YAN CAM KILIF SACI BOYALI				1	1	1				PCS
	49700005	SOLI 1500 CAMLI YAN CAM KILIF SACI BOYALI							1	1	1	PCS
27	23610604	MARKET UST CAM DIK RODAJLI KRISTAL (937x170x8 mm.)	2			2			2			PCS
	23610603	MARKET UST CAM DIK RODAJLI KRISTAL (1250x170x8 mm.)		2	3		2	3		2	3	PCS





	CAREL PARAM	METERS	ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK
/Pro ( Prob	parameters)		•					
/2	Measurement stability		4	4	4	4	4	4
	Virtual Prob: Blowing and suction probes rates for regulation							
/4	0= Blow probe		100	100	100	50	50	50
	100= Suction probe							
/5	ºC or ºF selection		0	0	0	0	0	0
/3	0=°C, 1=°F		U	U	U	U	0	U
	Decimal		1	1	1	1	1	1
/6	0=active,		_	_	_			_
	1= inactive							
	Virtual probe regulation rate to calculate glass temperature			20				
rHS	0= Blow probe 100= Suction probe				20	20	20	20
	Are signals and alarms viewed in non-button terminal?		0	0	0	0	0	0
/t	0= inactive		Ŭ	Ŭ	Ŭ			ŭ
	1= active							
	probe to be viewed in button terminal							
	0 = Terminal inactive	8 =Serial probe 8						
	1 = Probe 1	9 =Serial probe 9						
	2 = Probe 2	10 =Serial probe 10						
/t1	3 = Probe 3	11 =Serial probe 11	12	12	12	12	12	12
	4 = Probe 4	12 = Control probe	]					
	5 = Probe 5	13 = Virtual probe						
	6 = Probe 6	14 = Set point	]					
	7 = Probe 7							
	probe to be viewed in non-button terminal							
	0 = Terminal inactive	8 =Serial probe 8	]					
	1 = Probe 1	9 =Serial probe 9	]					
	2 = Probe 2	10 =Serial probe 10	[					
/t2	3 = Probe 3	11 =Serial probe 11	12	12	12	12	12	12
	4 = Probe 4	12 = Control probe	]					
	5 = Probe 5	13 = Virtual probe						
	6 = Probe 6	14 = Set point						
	7 = Probe 7							

	CAREL PARAM	METERS	ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK
	button/non-button terminal configuration							
	Button terminal	Non-button terminal						
/to	0 Yes	yes	3	3	3	3	3	3
/ 10	1 optional	yes	]					
	2 Yes	optional	]					
	3 optional	optional						
	S1,S2,S3 (Group 1) probe type							
	0 = NTC Standard Range -50T90°C		]					
/P1	1 = PTC Standard Range -50T150°C		0	0	0	0	0	0
	2 = PT1000 Standard Range -50T150°C		]					
	3 = NTCL243 Standard Range -50T90°C							
	S4 ,S5 (Group2) probe type							
	0 = NTC Standard Range -50T90°C							
/P2	1 = PTC Standard Range -50T150°C		0	0	0	0	0	0
	2 = PT1000 Standard Range -50T150°C							
	3 = NTCL243 Standard Range -50T90°C							
	S6 (Group3) probe type		]					
	0 = NTC Standard Range -50T90°C							
/P3	1 = PTC Standard Range -50T150°C		4	4	4	4	4	4
/ / / /	2 = PT1000 Standard Range -50T150°C		4	4	4	4	4	4
	3 = NTCL243 Standard Range -50T90°C							
	4 = 0 to 5V ratiometric pressure transmitter							
	S7, (Group4) probe type							
	0 = NTC Standard Range -50T90°C							
	1 = PTC Standard Range -50T150°C							
/P4	2 = PT1000 Standard Range -50T150°C	0T150°C	0	0	0	0	0	0
/ / / /	3 = NTCL243 Standard Range -50T90°C				"	U	U	0
	4 = 0 to 5V ratiometric pressure transmitter							
	5 = 0 to 10 V input							
	6 = 4 to 20 mA input		<u> </u>					
/P5	S8 den S11 e (Group5) serial problar probe type		0	0	0	0	0	0

	CAREL PARAM	IETERS	ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK
	Sm Blow probe connection point							
	0 = Function inactive	6 = Probe S6						
	1 = Probe S1	7 = Probe S7						1
/FA	2 = Probe S2	8 = Serial probe S8	1	1	1	1	1	1
	3 = Probe S3	9 = Serial probe S9						
	4 = Probe S4	10 = Serial probe S10						
	5 = Probe S5	11 = Serial probe S11						
/Fb	See Sd defrost probe connection point/FA parameter probe list		2	2	2	2	2	2
/Fc	See Sr Suction probe connetion point /FA parameter probe list		3	3	3	3	3	3
/Fd	See tGS superheat temperature sensor connection point /FA parameter probe list  See Peu/tEu superheat pressure transmitter connection point /FA parameter probe list  See Sd2 2. evaporator defrost probe connection point /FA parameter probe list	4	4	4	4	4	4	
/FE	See Peu/tEu superheat pressure transmitter connection point /FA	parameter probe list	6	6	6	6	6	6
/FF	See Sd2 2. evaporator defrost probe connection point /FA parame	ter probe list	5	0	0	0	0	0
/FG	See Saux1 auxiliary temperature probe connection point /FA para	meter probe list	0	0	0	0	0	0
/FH	See Saux1 auxiliary temperature probe connection point /FA parameter probe list See Saux2 auxiliary temperature probe connection point /FA parameter probe list		0	0	0	0	0	0
/FI	See SA ambient temperature probe connection point /FA paramet	er probe list	0	0	0	0	0	0
/FL	See SU ambient moisture probe connection point /FA parameter p	probe list	0	0	0	0	0	0
/FM	See Svt glass temperature probe connection point /FA parameter	probe list	0	0	0	0	0	0
	See Sdp dewing point serial probe connection point							
/Fn	0 = Function inactive	3 = Serial probe S10	0	0	0	0	0	0
''''	1 = Serial probe S8	4 = Serial probe S11		0	U	U	U	
	2 = Serial probe S9							
/c1	Probe 1 calibration. If pushed twice, shows the value read by the p	probe	0	0	0	0	0	0
/c2	Probe 2 calibration. If pushed twice, shows the value read by the p		0	0	0	0	0	0
/c3	Probe 3 calibration. If pushed twice, shows the value read by the p	probe	0	0	0	0	0	0
/c4	Probe 4 calibration. If pushed twice, shows the value read by the p	probe	0	0	0	0	0	0
/c5	Probe 5 calibration. If pushed twice, shows the value read by the p		0	0	0	0	0	0
/c6	Probe 6 calibration. If pushed twice, shows the value read by the p	robe	0	0	0	0	0	0
/c7	Probe 7 calibration. If pushed twice, shows the value read by the p	robe	0	0	0	0	0	0
/U6	Probe 6 maximum scale value		9.3	9.3	9.3	9.3	9.3	9.3
/L6	Probe 6 minimum scale value		-1	-1	-1	-1	-1	-1
/U7	Probe 7 maximum scale value		9.3	9.3	9.3	9.3	9.3	9.3
/L7	Probe 7 minimum scale value		-1.0	-1.0	-1.0	-1.0	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	-1.0

	CAREL PARAM	METERS	ISLAND FREEZER	WALL FREEZER	COMBI	UPRIGHT FREEZER	COUNTER	MULTIDECK
CtL (Contro	1)							
OFF	ON/OFF control unit on-off		0	0	0	0	0	0
	0 = ON; 1 = OFF;							
St	Set point		-20	-20	-20	-20	0	2
St2	Double thermostate control suction set value		50	50	50	50	50	50
rd	St set value difference		2	2	2	2	2	2
rd2	Double thermostate control suction set value difference		0	0	0	0	0	0
102	0.0 = Function inactive		Ŭ					Ŭ
r1	Allowed minimum set value		-24	-24	-24	-24	-4	-4
r2	Allowed maximum set value		-18	-18	-18	-18	4	4
r3	Defrost warning activation ending in time		0	0	0	0	0	0
	0 = inactive, 1 = active							Ů
r4	Automatic night set point		0	0	0	0	0	0
	Will minimum and maximum temperatures be kept to which prob							
	0 = Monitoring inactive	6 = superheat temperature probe(tGS)						
	1 = Control probe (Sreg)	7 = saturated evaporation temperature probe (tEu)						
r5	2 = virtual probe (Sv)	8 = auxiliary defrost probe (Sd2)	1	1	1	1	1	1
	3 = Blow probe (Sm)	9 = auxiliary probe (Saux)						
	4 = defrost probe (Sd)	10 = auxiliary probe 2 (Saux2)						
	5 = Suction probe (Sr)							
rt	Recorded min and max temperature monitoring time range		-	-	-	-	-	-
rH	Recorded max temperature		-	-	-	-	-	-
rL	Recorded min temperature		-	-	-	-	-	-
r6	Night Control probe		0	0	0	0	0	0
10	0 = virtual probe Sv; 1 = Suction probe Sr		Ü	U	U	U	0	U
ro	For Virtual Probe, probe error offset		0.0	0.0	0.0	0.0	0.0	0.0
r7	Master solenoid valve configuration		0	0	0	0	0	0
.,	0 = local valve ;1 = network valve (connected to the Master)				0	U		·
rSu			0	0	0	0	0	0

	CAREL PARAM	ETERS	ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK
CMP (compi	ressor)		•					
c0	Compressor and fan starting time delay		0	0	0	0	0	0
<b>c1</b>	Minimum time between successive start		0	0	0	0	0	0
c2	Compressor minimum OFF Time		0	0	0	0	0	0
c3	Compressor minimum ON Time		0	0	0	0	0	0
	Control probe error duty time. Compressor and solenoid outlet wo	rks for the time stated there						
c4	holds for 15 minutes and works again.		0	0	0	0	0	0
	0 = Compressor/valve always OFF; 100 = compressor/valve always	ON						
СС	Continuous cycle time		1	1	1	1	1	1
c6	Post-continuous cycle alarm by-pass		60	60	60	60	60	60
с7	Maximum pump down time		0	0	0	0	0	0
Def (defrost	:)							
	Defrost type							
	0 =temperature-based heater	4 =time and temperature-based heater defrost						
d0	1 = temperature-based hot gas	5 =temperature-based heater multiplied hotgas bypass	4	0	0	0	0	0
	2 = temperature-based heater	6 =time-based heater multiplied hotgas bypass						
	3 = time-based hot gas							
d2	Defrost-end synchronization by Master		1	1	1	1	1	1
uz	0 = unsynchronous; 1 = synchronous		1	1	1	1	1	1
dl	Time between defrosts		8	8	6	6	6	6
dt1	Defrost-end temperature, Evaporator Sd1		10	10	12	12	10	10
dt2	Defrost-end temperature, AUX Evaporator Sd2		10	10	12	12	10	10
dP1	Maximum Defrost time		35	35	40	45	45	45
dP2	Maximum Defrost time, AUX 2. Evaporator		35	35	40	45	45	45
	Initially defrost							
d4	0 = No initial defrost; 1 = inital defrost		0	0	0	0	0	0
	(Master = network defrost; Slave = local defrost)							
d5	Defrost time delay at the beginning if d4=1		0	0	0	0	0	0
us	0 = delay inactive		0	U	U	U	U	U
	Terminal indicator status during defrost							
d6	0 = Real temperature value and "dEF" flashes		2	2	2	2	2	2
l ub	1 = pre-defrost last temperature remains on the screen					2		
	2 = 'dEF' is viewed							
dd	Post-Defrost drip time		2	2	2	2	2	2
uu	0= No drip							

defrost by-pass		CAREL PARAM	TETERS	ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK
Main   Alarm delay following defrost and door opening   30   30   30   30   30   30   30   3	d7			0	0	0	0	0	0
Status of compressor protection times in hotgas bypass   1	d8			30	30	30	30	30	30
Sd1   Defrost Probe Value   Sd2   Defrost Probe Value   Second Evaporator defrost probe value   Sd2   Sd2									
Sd1   Defrost Probe value	d9		d	1	1	1	1	1	1
Defrost time basis   O	Sd1			-	-	-	-	-	-
dC         0 = dl hour,dP1,dP2 and ddP minute; 1 = dl minute,Dp2 and ddP second         0 <t< td=""><td>Sd2</td><td>Second Evaporator defrost probe value</td><td></td><td>-</td><td>-</td><td>-</td><td>-</td><td>-</td><td>-</td></t<>	Sd2	Second Evaporator defrost probe value		-	-	-	-	-	-
1 = dl minute,Dp2 and ddP second		Defrost time basis							
Time for defrost based on lamel temperature   0	dC	0 = dl hour,dP1,dP2 and ddP minute;		0	0	0	0	0	0
Compressor stop time for successive defrost (defrost starts when the did befrost time offset for Power defrost   Compressor operation time for successive defrost (defrost starts when the did ly defrost based on td1 time zone   Compressor ominute   Compressor		1 = dl minute,Dp2 and ddP second							
Definition inactive   -30 -30 -30 -30 -30 -30 -30 -30 -30 -30	410	Time for defrost based on lamel temperature			0	0	0	0	0
During Defrost, pressure transmitter alarm status   probe failure   failure in supervisor   0   inactive   active   active   1   active   active   active   2   inactive   inactive   inactive   0   0   0   0   0   0   0   0   0	uio	0 = Function inactive			U	U	U	U	U
Defrost processor operation time for successive defrost (defrost starts when the substitute of the processor time for successive defrost (defrost starts when the substitute of the processor operation time for successive defrost (defrost starts when the substitute of the processor operation time for successive defrost (defrost starts when the substitute of the processor operation time for successive defrost (defrost starts when the substitute of the processor operation time for successive defrost (defrost starts when the substitute of the processor operation time for successive defrost (defrost starts when the substitute of the processor operation time for successive defrost (defrost starts when the substitute of the processor operation time for successive defrost starts when the substitute of the processor operation time for successive defrost starts when the substitute of the processor operation time for successive defrost defrost starts when the substitute of the processor operation time for successive defrost defrost starts when the substitute of the processor operation time for successive defrost defrost ends, or substitute of the processor operation time for successive defrost defrost ends, or substitute of the processor operation time for successive defrost defrost ends, or substitute of the processor operation time for successive defrost defrost ends, or substitute of the processor operation time for successive defrost defrost ends, or substitute of the processor operation time for successive defrost defrost ends, or substitute of the processor operation time for successive defrost defr	d11	Temperature-based defrost activation temperature threshold		-30	-30	-30	-30	-30	-30
d12									
active       active         2 inactive       inactive         3 active       inactive         Compressor stop time for successive defrost (when stops for this time, defrost ends, 0 = Function inactive)       0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0			failure in supervisor	_					
1 active   active   inactive   inactive	d12	0 inactive	active	0	0	0	0	0	0
Solution   Solution			active	]	Ŭ				
Compressor stop time for successive defrost ( when stops for this time, defrost ends,									
Compressor operation time for successive defrost (defrost starts when the   120									
d52         Compressor operation time for successive defrost (defrost starts when the         120	dS1		time, defrost ends,	0	0	0	0	0	0
ddt         Defrost end temperature offset for Power defrost         0.0<									
ddp         Defrost time offset for Power defrost         0         0         0         0         0           dn         Nominal Defrost bypass time rate         75<		· · · · · · · · · · · · · · · · · · ·	when the						
dn         Nominal Defrost bypass time rate         75									
daily defrost based on td1 time zone         0 = inactive       8 = 3 hours 0 minute         1 = 24 hours 0 minute       9 = 2 hours 40 minutes         2 = 12 hours 0 minute       10 = 2 hours 24 minutes         3 = 8 hours 0 minute       11 = 2 hours 11 minutes         4 = 6 hours 0 minute       12 = 2 hours 0 minute         5 = 4 hours 48 minutes       13 = 1 hour 0 minute         6 = 4 hours 0 minute       14 = 30 minutes	<u> </u>								
0 = inactive       8 = 3 hours 0 minute         1 = 24 hours 0 minute       9 = 2 hours 40 minutes         2 = 12 hours 0 minute       10 = 2 hours 24 minutes         3 = 8 hours 0 minute       11 = 2 hours 11 minutes         4 = 6 hours 0 minute       12 = 2 hours 0 minute         5 = 4 hours 48 minutes       13 = 1 hour 0 minute         6 = 4 hours 0 minute       14 = 30 minutes	dn			/5	/5	/5	/5	/5	/5
1 = 24 hours 0 minute       9 = 2 hours 40 minutes         2 = 12 hours 0 minute       10 = 2 hours 24 minutes         3 = 8 hours 0 minute       11 = 2 hours 11 minutes         4 = 6 hours 0 minute       12 = 2 hours 0 minute         5 = 4 hours 48 minutes       13 = 1 hour 0 minute         6 = 4 hours 0 minute       14 = 30 minutes		·	0 2 h 2 m 2 0 m i 2 m i	-					
2 = 12 hours 0 minute				-					
d1S       3 = 8 hours 0 minute       11 = 2 hours 11 minutes       0				-					
4 = 6 hours 0 minute12 = 2 hours 0 minute5 = 4 hours 48 minutes13 = 1 hour 0 minute6 = 4 hours 0 minute14 = 30 minutes	410			0	0	0	0	0	0
5 = 4 hours 48 minutes 13 = 1 hour 0 minute 6 = 4 hours 0 minute 14 = 30 minutes	uıs			1	U			0	
6 = 4 hours 0 minute 14 = 30 minutes				1					
				1					
			14 - 30 IIIIIIutes	1					

	CAREL PARA	METERS	ISLAND	WALL FREEZER	COMBI	UPRIGHT	COUNTER	MULTIDECK
d2S	see d1S parameter for td1 time zone daily defrosts		0	0	0	0	0	0
dH1	Pumpdown time		0	0	0	0	0	0
uni	0= pump down inactive		U	U	U	U	U	U
	Multiplied hot gas bypass type							
dHG	0 = Compensator valve is OFF usually		0	0	0	0	0	0
	1 = Compensator valve is ON usually							
ALM (Alarn								
	Determination of temperature probe for AH and AL alarms							
	1 = control (sreg)	8 = auxiliary defrost probe (Sd2)						
	2 = virtual (Sv)	9 = auxiliary probe (Saux)						
AA	3 = blow (Sm)	10 = auxiliary probe 2 (Saux2)	1	1	1	1	1	1
	4 = defrost (Sd)	11 = ortam sıcaklığı (SA)		_	_	_	_	_
	5 = suction (Sr)	12 = ortam nemi (SU)						
	6 = superheat temperature probe(tGS)	13 = cam sıcaklıklığı (Syt)						
	7 =SH pressure transmitter temperature equivalence (tEu)	14 = çiğlenme noktası (SdP)						
AA2	Determination of temperature probe for AH2 and AL2 alarms co	ntrol AA parameter	5	5	5	5	5	5
A0	Low and high temperature alarm difference		2.0	2.0	2.0	2.0	2.0	2.0
	Threshold type for AL and AH 1. Alarm delays							
A1	0 = relative AL and AH set value		0	0	0	0	0	0
	1 = absolute AL and AH absolute values							
	Threshold type for AL2 and AH2 2. Alarm delays							
A2	0 = relative AL and AH set value		0	0	0	0	0	0
	1 = absolute AL and AH finite values							
AL	Low temperature 1. alarm threshold		4	4	4	4	4	4
AH	High temperature 1. alarm threshold		5	5	5	5	5	5
AL2	Low temperature 2. alarm threshold		0	0	0	0	0	0
AH2	High Temperature 2. alarm threshold		0	0	0	0	0	0
Ad	Low and high temperature alarm alarm delay		15	15	15	15	15	15
	ID1 digital input configuration in S4 input							
	0 = input is not active	5 = kapı switci konfigürasyonu kompresör ve fanlar OFF						
A4	1 = momentary external alarm	6 = uzaktan ON/OFF	0	0	0	0	0	0
^4	2 = delayed external alarm	7 = perde switchi						
	3 = defrost activation	8 = sürekli çevrim başlama / durma						
	4 = defrost starting	9 = ışık sensörü						

	CAREL PARAMETERS	ISLAND	WALL FREEZER	COMBI	UPRIGHT	COUNTER	MULTIDECK
A5	ID2 digital input configuration in S5 input, see the list in A4 parameter	0	0	0	0	0	0
	In the event of external alarm, solenoid/compressor working times. Compressor and solenoid						
A6	work for this time, stop for 15 minutes and work againn.	0	0	0	0	0	0
	0 = Compressor/valve always OFF; 100 = compressor/valve always ON	1					
A7	Time delay for delayed external alarm	0	0	0	0	0	0
A8	Virtual digital input configuration see the list in A4 parameter	0	0	0	0	0	0
	Digital input selection transferred from master to slave						
A09	0 = supervisor 3 = D13	0	0	0	0	0	0
A03	1 = D11 4 = D14	]			U	U	
	2 = D12 5 = D15						
A10	ID3 digital input configuration in S6 input see the list in A4 parameter	0 0	0	0	0	0	0
A11	Id4 digital input configuration in S7 input, see the list in A4 parameter	0	0	0	0	0	0
A12	Digital input configuration in DI5 input, see the list in A4 parameter	0	0	0	0	0	0
Ar	Is alarm signal in slaves shown in master?	1	1	1	1	0 0 0 0	1
	0 = no ; 1 = yes				_		_
	When slaves are offline, hotgas bypass procedure	1					
A13	0 = inactive	0	0	0	0	0	0
	1 = active						
Fan (Evapor	rator fans)						
	Evaporator fan management	]					
F0	0 = always ON	0	0	0	0	0	0
'	1 = Fan activation Sd defrost - Sv virtual (or Sd defrost - Sm blow double thermostat control)	J			U	U	
	2 =Activation Sd defrost probe						
F1	Fan activation threshold (only F0=1 and 2)	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0
	Will fans stop when the compressor stops?	1					1
F2	0 =Fans work	0	0	0	0	0	0
	1 = Fans stop						
	Status of fans during defrost	1				1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
F3	0 = Fans work in Defrost	0	0	1	1	0	0
	1 = fans stop						
Fd	Post-defrost drip fan waiting time	2	2	2		2	2
Frd	Fan activation difference (including variable speed fans)	2.0	2.0	2.0	2.0		2.0
F5	Evaporator fan stop threshold (difference 1C)		50.0	50.0	50.0		50.0
F6	Maximum Evaporator fan speed	100	100	100	100	100	100

	CAREL PARAMETERS	ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK
F7	Minimum Evaporator fan speed	0	0	0	0	0	0
F8	Evaporator fan peak time 0 = Function inactive	0	0	0	0	0	0
F9	PWM1/' fan control output selection (by phase-break)  0 = pulse  1 = time-dependant	1	1	1	1	1	1
F10	Time of working of evaporator fans at maximum speed  0 = Function inactive	0	0	0	0	0	0
<b>Eud (Electro</b>				L			
P1	Electronic valve  0 = not used  1 = PWM valve  2 = CAREL E2V valve	2	2	2	2	2	2
Р3	Superheat Set point	10.0	10.0	10.0	10.0	10.0	10.0
P4	Proportional rate	15.0	15.0	15.0	15.0	15.0	15.0
P5	Integration rate (Integral factor)  0 = Function inactive	150	150	150	150	150	150
Р6	Derivative rate  0 = Function inactive	5.0	5.0	5.0	5.0	5.0	5.0
P7	LowSH: low superheat threshold	7.0	7.0	7.0	7.0	7.0	7.0
P8	LowSH: low superheat integral time  0 = Function inactive	15.0	15.0	15.0	15.0	15.0	15.0
Р9	LowSH: düşük superheat alarm gecikmesi  0 = alarm inactive	600	600	600	600	600	600
P10	Will solenoid valve be OFF in the event of low superheat or low suction temperature?  1 = OFF is active	0	0	0	0	0	0
P11	LSA: low evaporation temperature alarm	-45.0	-45.0	-45.0	-45.0	-45.0	-45.0
P12	LSA: alarm delay 0 = alarm inactive	600	600	600	600	600	600
P13	LSA: alarm difference (C)  0 = reset the alarm all the time automatically	10.0	10.0	10.0	10.0	10.0	10.0
P14	('blo') alarm signal activation  1= blo alarm is active	1	1	1	1	1	1
P15	Complementary temperature acceptance value in the event of Superheat pressure	-30	-30	-30	-12	-12	-12

	CAREL PARAMETERS	ISLAND	WALL FREEZER	COMBI	UPRIGHT FREEZER	COUNTER	MULTIDECK
	Gas type						
	1 = R22 8 = R600						
	2 = R134a 9 = R600a						
PH	3 = R404A	3	3	3	3	3	3
	4 = R407C						
	5 = R410A	ļ					
	6 = R507A						
-	7 = R290						
OSH	Superheat offset for modulation thermostate	0.0	0.0	0.0	0.0	0.0	0.0
-	0 = Function inactive						
Phr	Fast updating of valve parameters by the supervisor	0	0	0	0	0	0
PM1	0 = fast update is inactive	50.0	50.0	50.0	50.0	50.0	50.0
PM2	MOP: Maximum evaporation pressure temperature value	10.0	10.0	10.0	10.0	10.0	10.0
PIVIZ	MOP: Integral time MOP: alarm delay	10.0	10.0	10.0	10.0	10.0	10.0
PM3	0 = Function is inactive	0	0	0	0	0	0
PM4	MOP: MOP function delay at the beginning	2	2	2	2	2	2
FIVI	MOP: activating solenoid valve shutting						
PM5	0 = OFF is inactive	0	0	0	0	0	0
FIVIS	1 = OFF is active		U	U	U	0	
PL1	LOP: Minimum evaporation pressure temperature value	-50.0	-50.0	-50.0	-50.0	-50.0	-50.0
PL2	LOP: Integral time	0.0	0.0	0.0	0.0	0.0	0.0
	LOP: alarm delay	0.0	0.0	0.0	0.0	0.0	0.0
PL3	0 = Functionis inactive	0	0	0	0	0	0
SH	Superheat value	_	_	-	_	_	_
PPU	valve ON rate	_	-	_	_	_	_
tGS	Superheat temperature sensor reading value	_	-	_	_	_	-
tEu	Superheat pressure sensor temperature value (value of the pressure equivalent to the temperature)	-	-	-	_	-	_
/cE	Saturated evaporation temperature calibration	0.0	0.0	0.0	0.0	0.0	0.0
Po6	PWM expansion valve T on/OFF period	6	6	6	6	6	6
cP1	Valve position when the control is ON	30	30	30	30	30	30
Pdd	Post-Defrost valve position	10	10	10	10	10	10
PSb	valve standby position	0	0	0	0	0	0
PF	valve opening stages	-	-	-	-	-	-

	CAREL PA	RAMETERS	ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK			
	Electronic expansion valve manual operation activation										
PMP	0 = inactive		0	0	0	0	0	0			
	1 = active										
PMu	Manual valve position		-	-	-	-	-	-			
Phc	Large capacity valve activation		0	0	0	0	0	0			
Cnf (Config			•		•	•	•	•			
	MPXPRO Unit type										
In	0 = Slave		1	1	1	1	1	1			
	1 = Master										
	Number of slave in local network					_					
Sn	0 = No Slave		0	0	0	0	0	0			
НО	Supervisor and Master-Slave network adrdess		199	199	199	199	199	199			
	AUX1 output configuration										
	0 = no function	7 = second Evaporator defrost output									
	1 = alarm without energy normally	8 = Evaporator Fan output									
H1	2 = energy alarm normally	9 = Glass heater output		8	8	8	8 8	8	8	8	8
	3 = auxiliary output	10 = Suction valve	•					0	0	0	
	4 = auxiliary output shared by Master with slaves	11 = Compensation valve									
	5 = Light output	12 = Solenoid valve									
	6 = auxiliary output shared by Master with slaves										
H2	Button set and remote control deactivation		1	1	1	1	1	1			
112	1 = Button set and remote control is active				_	1		_			
Н3	Remote control activation code		0	0	0	0	0	0			
113	0 =no remote control activation code		Ŭ	Ů	Ů	Ů	Ů	Ů			
H4	Buzzer activation		0	0	0	0	0	0			
	0 = active; 1 = inactive			Ŭ			Ů	,			
H5	Please see AUX2 output configuration H1 parameter		7	2	2	2	2	2			
Н6	Terminal button set locking configuration		0	0	0	0	0	0			
H7	Please see AUX3 output configuration H1 parameter		5	5	5	5	5	5			
	Output association with time bands										
Н8	0 = Light		0	0	0	0	0	0			
	1 = AUX										

	CAREL PARAMETERS	ISLAND	WALL	COMBI	UPRIGHT FREEZER	COUNTER	MULTIDECK
	Output association with AUX button						
Н9	0 = Light	0	0	0	0	0	0
	1 = AUX						
	Compressor output configuration						
H10	0 = Cooling	0	0	0	0	0	0
	1 = heating						
	Fan output configuration						
H11	0 = Cooling	0	0	0	0	0	0
	1 = Heating						
H12	Light sensor threshold	25	25	25	25	25	25
H13	Please see AUX4 output configuration H1 parameter	12	12	12	12	12	12
Hdn	default set parameters number	0	0	0	0	0	0
Htc	External time card insertion	0	0	0	0	0	0
ни	0 = not inserted	U	U	U	U	0	U
rHu	Manual glass heater activation rate (rHt period)	70	70	70	70	70	70
	0 = Function is inactive	70	70	70	70	70	70
rHt	Manual glass heater activation period	5	5	5	5	5	5
	0 = Function is inactive						
rHo	Glass heater modulation offset	2.0	2.0	2.0	2.0	2.0	2.0
rHd	Glass heater modulation difference	0.0	0.0	0.0	0.0	0.0	0.0
	PWM output load type for glass heater modulation	ļ					
rHL	0 = resistant	0	0	0	0	0	0
	1 = inductive						
	Factor A for calculated glass temperature	2	2	2	2	2	2
rHb	Factor B for calculated glass temperature	22	22	22	22	22	22
HSt (Alarm I		ı			-		
	0 dan 9'a alarmlar (sete basın)	-	-	-	-	-	-
	0 dan 9'a alarm kodu	-	-	-	-	-	-
h_	0 dan 9'a alarm houri	0	0	0	0	0	0
	0 dan 9'a alarm minutesi	0	0	0	0	0	0
HcP (HACCP	0 dan 9'a alarm süresi	0	0	0	0	0	0
	<del>, '</del>	I 0	0	0	0	0	
	HACCP alarm	0	0	0	0	0	0
MAN	HA alarm type number	U	U	U	U	U	U

	CAREL PARAMETERS	ISLAND	WALL	COMBI	UPRIGHT FREEZER	COUNTER	MULTIDECK
HA to HA2	2 HA type active HACCP alarm number From 1 to 3 alarm - Year From 1 to 3 alarm - which day of the month From 1 to 3 alarm - which day of the month From 1 to 3 alarm - hour From 1 to 3 alarm - minute From 1 to 3 alarm - minute HF alarm type number 2 HF type active HACCP alarm number From 1 to 3 alarm - Year From 1 to 3 alarm - Wear From 1 to 3 alarm - which day of the month From 1 to 3 alarm - which day of the month From 1 to 3 alarm - which day of the month From 1 to 3 alarm - Alarm time HACCP alarm delay 0 = alarm wilewing deactivated Ime clock) Defrost time from 1 to 8 (press Set) From 1 to 8 defrost day selection 0 = no defrost 1 to 7 = days one by one from Monday to Sunday 8 = every day from Monday to Friday 9 = everyday from Monday to Saturday 10 = only Saturday Sunday 11 = everyday Defrost shour Defrost shour Defrost minute Power defrost selection 0 = Normal defrost; 1 = Power defrost Time band starting from 1 to 8 (press Set) Time band starting from 1 to 8 (press Set) Time band starting; day Time band starting; hour		-	-	-	-	-
У_	From 1 to 3 alarm-Year	0	0	0	0	0	0
M_	From 1 to 3 alarm - month	0	0	0	0	0	0
d_	From 1 to 3 alarm - which day of the month	0	0	0	0	0	0
h_	From 1 to 3 alarm - hour	0	0	0	0	0	0
n_	From 1 to 3 alarm - minute	0	0	0	0	0	0
•••	From 1 to 3 alarm - Alarm time	0	0	0	0	0	0
HFn	HF alarm type number	0	0	0	0	0	0
HF to HF2	HF type active HACCP alarm number	-	-	-	-	-	-
У_	From 1 to 3 alarm - Year	0	0	0	0	0	0
M_	From 1 to 3 alarm -month	0	0	0	0	0	0
d_	From 1 to 3 alarm - which day of the month	0	0	0	0	0	0
h_	From 1 to 3 alarm - hour	0	0	0	0	0	0
n_	From 1 to 3 alarm - minute	0	0	0	0	0	0
_	From 1 to 3 alarm - Alarm time	0	0	0	0	0	0
		0	0	0	0	0	0
		U	U	U	U	0	Ŭ
rtc (Real Tim	•						
		-	-	-	-	-	-
	From 1 to 8 defrost day selection						
		0	0	0	0	0	0
	1 to 7 = days one by one from Monday to Sunday	U	U	U	O	U	
d_	8 = every day from Monday to Friday						
	9 = everyday from Monday to Saturday						
	10 = only Saturday Sunday						
h	Defrost hour	0	0	0	0	0	0
n_		0	0	0	0	0	0
P_		0	0	0	0	0	0
'-				J	J		Ŭ
tS1 to 8		-	-	-	-	-	-
d		0	0	0	0	0	0
h		0	0	0	0	0	0
n	Time band starting: minute	0	0	0	0	0	0
tE1 to 8	Time band end from 1 to 8 (press Set)	-	-	-	-	-	-

	CAREL PARAMETERS	ISLAND	WALL FREEZER	COMBI	UPRIGHT	COUNTER	MULTIDECK
d	Time band end: day	0	0	0	0	0	0
h	Time band end: hour	0	0	0	0	0	0
n	Time band end: minute	0	0	0	0	0	0
tc	Real date/hour (press Set)	-	-	-	-	-	-
,,	Date/hour: year	REAL	REAL	REAL	REAL	REAL	REAL
У_		TIME	TIME	TIME	TIME	TIME	TIME
M_	Date/hour: month	REAL	REAL	REAL	REAL	REAL	REAL
		TIME	TIME	TIME	TIME	TIME	TIME
	Date/hour: which day of the month	REAL	REAL	REAL	REAL	REAL	REAL
d_		TIME	TIME	TIME	TIME	TIME	TIME
	Date/hour: which day of the week	REAL	REAL	REAL	REAL	REAL	REAL
u_		TIME	TIME	TIME	TIME	TIME	TIME
h	Date/hour: hour	REAL	REAL	REAL	REAL	REAL	REAL
h_		TIME	TIME	TIME	TIME	TIME	TIME
n	Date/hour: minute	REAL	REAL	REAL	REAL	REAL	REAL
n_		TIME	TIME	TIME	TIME	TIME	TIME

	DANFOSS PARAMETERS	ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK
Normal o	peration						
	Temperature (setpoint)	-26	-20	-20	-20	0	2
Thermost							
	Differential	2	2	2	2	2	2
r02	Max. limitation of setpoint setting	-22	-18	-18	-18	-4	-4
	Min. limitation of setpoint setting	-29	-23	-23	-23	4	4
r04	Adjustment of temperature indication	0	0	0	0	0	0
r05	Temperature unit (°C/°F)	0	0	0	0	0	0
	Correction of the signal from S4	0	0	0	0	0	0
r10	Correction of the signal from S3	0	0	0	0	0	0
r12	Manual service, stop regulation, start regulation (-1, 0, 1)	1	1	1	1	1	1
r13	Displacement of reference during night operation	0	0	0	0	0	0
r14	Define thermostat function  1=ON/OFF  2=Modulating	1	1	1	1	1	1
r15	Definition and weighting, if applicable, of thermostat sen- sors - S4% (100%=S4, 0%=S3)	100	0	0	0	50	50
r16	Time between melt periods	0	0	0	0	0	0
r17	Duration of melt periods	0	0	0	0	0	0
r21	Temperature setting for thermostat band 2 . As differential use r01	-26	-20	-20	-22	0	0
r59	Correction of the signal from S6	0	0	0	0	0	0
r61	Definition and weighting, if applicable, of thermostat sen- sors when night cover is on. (100%=S4, 0%=S3)	100	0	0	0	50	50
r62	Heat function	2	2	2	2	2	2
102	Neutral zone between refrigeration and heat function						2
r63	Time delay at switch between refrigeration and heat function	0	0	0	0	0	0
Alarms							
A03	Delay for temperature alarm	15	15	15	15	20	20
	Delay for door alarm	0	0	0	0	0	0
	Delay for temperature alarm after defrost	60	60	60	60	60	60
	High alarm limit for thermostat 1	-18	-15	-15	-15	4	6
	Low alarm limit for thermostat 1	-30	-26	-26	-26	-6	-6
	High alarm limit for thermostat 2	-18	-15	-15	-15	4	6
	Low alarm limit for thermostat 2	-30	-26	-26	-26	-6	-6
	High alarm limit for sensor S6 at thermostat 1	8	8	8	8	8	8
A23	Low alarm limit for sensor S6 at thermostat 1	-30	-30	-30	-30	-30	-30
	High alarm limit for sensor S6 at thermostat 2	8	8	8	8	8	8
A25	Low alarm limit for sensor S6 at thermostat 2	-30	-30	-30	-30	-30	-30

	DANFOSS PARAMETERS	ISLAND FREEZER	WALL FREEZER	COMBI	UPRIGHT	COUNTER	MULTIDECK
A26	S6 alarm time delay	240	240	240	240	240	240
A27	With setting = 240 the S6 alarm will be omitted  Alarm time delay or signal on the DI1 input	30	30	30	30	30	30
A27	Alarm time delay or signal on the DI2 input	30	30	30	30	30	30
A36	Signal for alarm thermostat. S4% (100%=S4, 0%=S3)	100	0	0	0	50	50
A52	Delay for S6 (product sensor alarm) after defrost	90	90	90	90	90	90
Compres		90	90	30	30	30	30
c01	Min. ON-time	0	0	0	0	0	0
c02	Min. OFF-time	0	0	0	0	0	0
c05	Time delay for cutin of comp.2	5	5	5	5	5	5
Defrost	Time delay for each or comple				3		
d01	Defrost method 0=off 1= EL 2= gAs	1	1	1	1	1	1
d02	Defrost stop temperature	10	10	12	12	10	10
d03	Interval between defrost starts	8	8	6	6	6	6
d04	Max. defrost duration	35	35	35	35	45	45
d05	Displacement of time on cutin of defrost at start-up	0	0	0	0	0	0
d06	Drip off time	2	2	2	2	3	3
d07	Delay for fan start after defrost	2	2	2	2	0	0
d08	Fan start temperature	-5	-5	-5	-5	-5	-5
	Fan cutin during defrost						
d09	0: Stopped	1	1	0	0	1	1
	1: Running						
	2: Running during pump down and defrost						
	Defrost sensor	ļ					
	0 =Stop on time	Į.					
-140	1=S5	_	4	4	4	4	
d10	2=S4	3	1	1	1	1	1
	3=Sx						
	(Application 1-8 and 10: both S5 and S6.						
44.0	Application 9: S5 and S5B)		0	0	0	- 0	
d16	Pump down delay	0	0	0	0	0	0
d17	Drain delay (used at hot gas defrost only)	0	0	0	0	0	0
d18	Max. aggregate refrigeration time between two defrosts	0	0	0	0	0	0
d20	Heat in drip tray. Time from defrosting stops to heating in the drip tray is switched off	30	30	30	30	30	30

	DANFOSS PARAMETERS	ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK CABINET
	Adaptive defrost:						
	0=not active,						
	1=monitoring only						
d21	2=skip allowed day	0	0	0	0	0	0
	3=skip allowed both day and night						
	4=own assessment						
	+ all schedules						
d23	Time delay before opening of hot gas valve	0	0	0	0	0	0
	Rail heat during defrost						
d27	0=off	2	2	2	2	2	2
u27	1=on			2			2
	2=Pulsating						
d40	Max. duration of -d- in display	30	30	30	30	30	30
Injection	control function						
n09	Max. value of superheat reference	12	12	12	12	12	12
n10	Min. value of superheat reference	3	3	3	3	3	3
n11	MOP temperature. Off if MOP temp. = 15.0 °C	15	15	15	15	15	15
n13	Period time of AKV pulsation	6	6	6	6	6	6
1113	Only for trained personnel	U	U	U	U	U	U
Fan							
	Fan stop temperature (S5)	50	50	50	50	50	50
	Pulse operation on fans:						
F05	0=No pulse operation	0	0	0	0	0	0
103	1=At thermostat cuts out only		0	O	O		O
	2= Only at thermostat cut outs during night operation						
	Period time for fan pulsation (on-time + off-time)	5	5	5	5	5	5
	On-time in % of period time	100	100	100	100	100	100
Real time		•	•			•	
t01-t06	Six start times for defrost. Setting of hours.	0	0	0	0	0	0
	0=OFF						
t11-t16	Six start times for defrost. Setting of minutes.	0	0	0	0	0	0
	0=OFF						
t07	Clock - Setting of hours	REAL	REAL	REAL	REAL	REAL	REAL
		TIME	TIME	TIME	TIME	TIME	TIME
t08	Clock - Setting of minute	REAL	REAL	REAL	REAL	REAL	REAL
.00		TIME	TIME	TIME	TIME	TIME	TIME

	DANFOSS PARAMETERS		ISLAND FREEZER	WALL	COMBI	UPRIGHT FREEZER	COUNTER	MULTIDECK CABINET
t45	Clock - Setting of date		REAL	REAL	REAL	REAL	REAL	REAL
-	Clock - Setting of month		TIME	TIME REAL	TIME REAL	TIME REAL	TIME REAL	TIME REAL
t46	Clock - Setting of month		TIME	TIME	TIME	TIME	TIME	TIME
	Clock - Setting of year			REAL	REAL	REAL	REAL	REAL
t47	t47 Clock Setting of year			TIME	TIME	TIME	TIME	TIME
Miscellar	neous		TIME					
o01	Delay of output signals after start-up		5	5	5	5	5	5
	Input signal on DI1. Function:							
	0=not used	7=thermostat band changeover (activate						
		r21)	_					
	1=status on DI1	8=alarm function when closed				0		0
o02	2=door function with alarm when open	9=alarm function when open	0	0	0	0	0	0
	3=door alarm when open	10=Appliance cleaning (pulse signal)	-					
	4=defrost start (pulse-signal)	11=forced cooling at hot gas defrost	-					
	5=ext.main switch	12=night cover	-					
003	6=night operation Network address	15=case shut down	0	0	0	0	0	0
003	On/Off switch (Service Pin message) IMPORTANT! o61 <b>must</b> be set prior to o04 (used at LON 485 an	nd DANIBLISS only)	Off	Off	Off	Off	Off	Off
005	Access code 1 (all settings)	Id DANBO33 Offiy)	0	0	0	0	0	0
003	Used sensor type		0	<u> </u>	U	U	U	U
006	0=Pt1000		0	0	0	0	0	0
	1=Ptc1000,		ď			Ŭ		
008			**	**	**	**	**	**
016			20	20	20	20	20	20
o17			100	0	0	0	50	50
o20	o20 Pressure transmitter working range – min. value			-1	-1	-1	-1	-1
o21	Pressure transmitter working range – max. value		12	12	12	12	12	12

		DANFOSS PARAMETERS		ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK CABINET
	Refrigerant setting:								
	1=R12	15=R227	29=R1270						
	2=R22	16=R401A	30=R417A						
	3=R134a	17=R507	31=R422A						
	4=R502	18=R402A	32=R413A						
	5=R717	19=R404A	33=R422D	_					
	6=R13	20=R407C	34=R427A						
o30	7=R13b1	21=R407A	35=R438A	19	19	19	19	19	19
	8=R23	22=R407	36=R513A						
	9=R500	23=R410A	37=R407F						
	10=R503	24=R170	38=R1234ze						
	11=R11	25=R290	39=R1234yf						
	12=R142b	26=R600	40=R448A						
	13=User defined	27=R600a	41=R449A						
	14=R32	28=R744	42=R452A						
o30	Refrigerant setting:			19	19	19	19	19	19
	Input signal on DI2. Function:								
	(0=not used.	5=ext. main switch	10=Appliance cleaning (pulse signal).						
o37	1=status on DI2.	6=night operation	11=forced cooling at hot gas defrost.).	0	0	0	0	0	0
037	2=door function with alarm when open.	7=thermostat band changeover (activate r21).	12=night cover,			0			0
	3=door alarm when open.	8=alarm function when closed.	13=coordinated defrost).						
	4=defrost start (pulse-signal).	9=alarm function when open.	15=case shut down						
	Configuration of light function:								
	1=Light follows day /night operation,								
o38	2=Light control via data communication via '	′o39′,		1	1	1	1	1	1
	3=Light control with a DI-input,								
		will open if the network cut out for more than 15 min	nutes.						
o39	Activation of light relay (only if o38=2) On=I	ight		Off	Off	Off	Off	Off	Off
o41	Rail heat On time during day operations			100	100	100	100	100	100
	Rail heat On time during night operations			100	100	100	100	100	100
o43	Rail heat period time (On time + Off time)			10	10	10	10	10	10
	Appliance cleaning.								
046	0=no Appliance cleaning.			0	0	0	0	0	0
040	1=Fans only.					0			
	2=All output Off.								
o61	Selection of EL diagram. See overview page 12 and 13			9	1	4	4	1	1
o62	Download a set of predetermined settings.	See overview page 27.		0	0	0	0	0	0

		DANFOSS PARAMETERS		ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK
o64	Access code 2 (partial access)	lace the controllers factory settings with the present settings  It signal on DI3. Function: (high voltage input)  Indicated 6-night operation, 12-night cover.  It status on DI2. 7-thermostat band changeover (activate r21) 13=Not used.  Indicated over function with alarm when open. 8=Not used. 14=Refrigeration stopped (forced closing)).  Indicated over function with alarm when open. 9=Not used. 15=case shut down  Indicated over function with alarm when open. 9=Not used. 15=case shut down  Indicated over function function function (o41 and o42), and o42), and o42), and o42), are signal indicated over function				0	0	0	0
o67						Off	Off	Off	Off
	(0=not used.								
	1=status on DI2.	<u> </u>							
084	2=door function with alarm when open.	8=Not used.		0	0	0	0	0	0
	(forced closing)).						Ĭ		
	4=defrost start (pulse-signal). 10=Appliance cleaning (pulse signal).								
	5=ext. main switch	11=forced cooling at hot gas defrost,							
	Rail heat control								
o85	0=not used,				0	0	0	0	0
		nd o42),		0			ľ		
	·								
o86	Dew point value where the rail heat is mini			8	8	8	8	8	8
o87	Dew point value where the rail heat is 100%	% on		17	17	17	17	17	17
088	Lowest permitted rail heat effect in %			30	30	30	30	30	30
o89	Time delay from "open door" refrigeration			30	30	30	30	30	30
	Fan operation at stopped cooling (forced cl	osing): 0= Stopped (defrost allowed)							
o90	1= Running (defrost allowed)			_ 1	1	1	1	1	1
	2= Stopped (defrost not allowed)			_					
	3= Running (defrost not allowed)								$\vdash$
	1=defrost stop temperature,								
o92	2=S6 temperature,			_ 1	1	1	1	1	1
	3=S5_B temperature (application 9), 4=S3B (application 10)								igsquare
	Display of temperature								
o97	2 do 7 iii terriperatare			1	1	1	1	1	1
	2= u36 product temperature								igsquare
	Light and night blinds defined								
o98				0	0	0	0	0	0
	1: Light and night blind is independent of main switch								

	DANFOSS PARAMETERS	ISLAND	WALL	COMBI	UPRIGHT	COUNTER	MULTIDECK
	Configuration of alarm relay						
	The alarm relay will be activated upon an alarm signal from the following groups:	_					
	1 - High temperature alarms						
	2 - Low temperature alarms						
P41	4 - Sensor error	1	1	1	1	1	1
	8 - Digital input enabled for alarm 16 - Defrosting alarms						
	32 - Miscellaneous 64 - Injection alarms						
	The groups that are to activate the alarm relay must be set by using a numerical value which is the sum of the groups that must be activated.						
	(E.g.: a value of 5 will activate all high temperature alarms and all sensor error and 0 will cancel the relay function).						